

Minutes of the Meeting

Date: 01.07.2011

Minutes of the Meeting held on 01.07.2011 at IACS with the intending bidders for “Electrical Installation work to provide power supply infrastructure to the Centenary Building of IACS, Jadavpur.”

Ref: NIT No. EI/053/Adm/11 dated 23.06.2011

As per terms of the NIT under reference, a meeting is held on 01.07.2011 in the Electrical Engineering Section Office with the intending bidders where the queries as raised by the bidders were duly addressed. After a thorough discussion, the following decisions have been made which may kindly be noted by the intending bidders before submission of their bid.

Item no. 2C: The dimension of the trench will be 400 mm (w) x 750 mm (d). However, the dimension of all other trench will be 750 mm (w) x 750 mm (w) for the cables to be laid direct in ground as scheduled.

List of make of cables & switchgear etc: It is mentioned in the next page.

Item no. 13b: The provision of 1 no. 125 A 4 Pole, 30 KA (release range 80-100 A, L&T make DU 125 type or similar superior approved make & model) MCCB as incomer to be deleted.

Item no. 14: Out of the 8 nos. way, only 6 nos. way will be utilised with DU100 MCCB, 3-Pole, 10KA, MCCB (release range: 100A, L&T make) at this stage. The remaining two nos. way will be kept as spare for future utilisation.

IP: The degree of protection for the DB enclosure / Panel to be fabricated will be minimum IP-42. However, higher degree of protection (IP 43 and above) is also acceptable to us.

Service tax etc: The rate should be inclusive of all taxes & duties including service tax and cess also. No service tax exemption will be available from IACS side. **NOTHING EXTRA WILL BE PAID TO THE CONTRACTOR OVER THE ACCEPTED RATE.**

Misc. Works (Item no. 15): The rate should only be quoted which will have no consideration on tender evaluation. However, if this item is required to be executed, the payment should be made on the basis of the accepted rate for this item.

SS Make: “SS make” may be noted as “similar superior” make subject to approval of IACS.

At the end of the meeting, site visit is made with all the bidders available and necessary site information are given to the satisfaction of the bidders.

With the change of the circumstances, IACS has extended the due date of submission of the bid up to 06.07.2011 (2.PM). However, no bid will be accepted beyond this date.

Contd. to page no. 2

LIST OF APPROVED MAKES

1.	MCCB	L&T/ABB/Siemens
2.	MCB/MCB DB	Legrand/Haggar's/ABB
3.	TPN Switches & HRC Fuses	L&T /Siemens / GE Power Controls
4.	Cables a) Upto 1.1KV grade b) Above 1.1KV grade	Polycab/Gloster/NICCO
5	Cable Lugs	Dowell's

NOTE:

The makes of material to be used shall be strictly as per choice of Client / Consultant which shall be binding on the contractor. For any item, if no make is mentioned, it will be considered to be ISI marked only.

Technical Officer (Electrical)
IACS, Jadavpur