

INDIAN ASSOCIATION FOR THE CULTIVATION OF SCIENCE
2A & 2B Raja S.C. Mullick Road, Jadavpur, Kolkata - 700032

Ref. No.- SCS/AD/18-19/95-1

DATE : 25-02-2019

CORRIGENDUM NOTICE No.- I

NIT No. - IACS/SCS/AD/2018-19/95 DATE : 14.02.2019

Technical Specification :

Based on the Pre-bid discussion with the vendors and OEMs, the following corrigendum is added to the tender specifications:

1. In table (vii), the entry “Monitor, Keyboard, Mouse” should read :

Monitor, Keyboard, Mouse	19” LED/LCD Monitor, USB Keyboard, USB Mouse Or 1U console with LED/LCD Monitor, Keyboard and Trackpad
-----------------------------	--

2. Table (viii) should read :

(viii) Compilers	
Intel cluster suite with perpetual license (network license std. 1 yr subscription)	
PGI compiler (Professional Edition) Fortran, C & C++ with perpetual academic license	
CUDA aware MPI on PGI compiler	
GPU RDMA (CUDA 6.0 or higher)	

3. Table (ix) should read :

(ix) UPS and power backup	
Technology	Online, IGBT based double conversion type
Output power factor	≥ 0.9
Total capacity	30 KVA (Output power 27 KW) as 3 x 10 KVA in parallel
Redundancy	3+1 (Four 10 KVA UPS in parallel)
Backup time	10 mins (approximately)
Input supply	3 phase
Output supply	1 phase

Acting Registrar